
Metropolitan Regional Housing Authority
Tender MET21-128 Switchboard Replacement Eastwood Manor
ADDENDUM NO. 2
August 18 2021

The Tender Documents shall be amended and will become part of the Contract Documents.

This addendum shall form an integral part of the Tender Documents:.

The contractor is to allow for the pick up and delivery of the temporary panel and wiring. The panel is located in the second level parking garage at 1 Alderney Dr Dartmouth and is to be returned when project is complete.

The closing date and time remains the same.

Metropolitan Regional Housing Authority
Tender MET21-128 Switchboard Replacement Eastwood Manor
ADDENDUM NO. 1
August 17 2021

The Tender Documents shall be amended and will become part of the Contract Documents.

This addendum shall form an integral part of the Tender Documents:.

In paragraph 2.9 of Section 26 24 02 (“Service Entrance Distribution Switchboard”) of the specification lists the acceptable manufacturers as: Schneider Electric, Eaton Canada, and Siemens.

ABB inc. has now been added to the list of acceptable manufacturers.

The closing date and time remains the same.