



To: *Proposed Bidders*

From: Peter Taylor, Purchasing Manager

Pages 1

Date: July 14, 2022

Re: Addendum 1 RFP 22-05OPP Roof Replacement Thorburn Consolidated School

The following comprises Addendum 1 for the above tender and will form part of the tender documents:

Tremco product Powerply Endure BIO Modified Bitumen Roof Membrane is an acceptable alternate for use in tender RFP 22-050PP with the following modifications/comments:

- 1. The specified cover board is used, not "BP ESGARD High Density Roof Insulator", as they've indicated.**
- 2. An inter-ply membrane is used, per the specifications (any one of the products listed in the report under the "Ply" section).**
- 3. The corner zones of the roof are mechanically fastened through the base sheet layer (as opposed to adhered), per the specifications.P**

This change did not require a revision to the Closing Date and Time.

If there is more than one (1) Addendum issued for this tender, please acknowledge each separately on your tender submission.

If your tender has already been submitted and this addendum changes your original proposal content, revised information can be emailed to tenders@ccrce.ca

If you have any questions, please advise.

Peter Taylor, Purchasing Manager
Chignecto Central Regional Centre for Education
60 Lorne Street
Truro, Nova Scotia
B2N 3K3